

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1200488

Product: PQ monitor

Type: MEg45PAN

Rating: Power supply: from measuring lines L1, L2 and L3 or 12 – 24 V DC,
Measuring: 3 x 300 V (L1, L2, L3 + N); CAT IV,
Current: 3 x 5A/1A; CAT II

Ordering firm: MEgA - Měřicí Energetické Aparáty, a.s.
Česká 390, 664 31 Česká, Czech Republic

Manufacturer: MEgA - Měřicí Energetické Aparáty, a.s.
Česká 390, 664 31 Česká, Czech Republic

Factories: MEgA - Měřicí Energetické Aparáty, a.s.
Česká 390, 664 31 Česká, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 021929-01/01 of: 30.09.2020, 021929-01/02 of: 30.09.2020

A sample of the product was found to be in conformity with:
ČSN EN 61010-1ed.2:2011+A1:2019, ČSN EN 61010-2-030:2011

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 021929 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 30.09.2023

01.10.2020

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



021929-01